



City of Doral

ITB No. 2021-05 - Telecommunications Wiring Services

Addendum No. 1

Below are questions/ clarifications that were received regarding this project as well as the City's responses. This Addendum is and does become a part of the above-mentioned solicitation. This addendum is issued to modify the subject solicitation as follows:

1. Do you anticipate extending the bid due date?
 - No as staff anticipates taking this item to the City Council for approval on March 17th, 2021.
2. What additional details are you willing to provide, if any, beyond what is stated in bid documents concerning how you will identify the winning bid?
 - Please refer to section 2.8 Method of award; there are no additional details available.
3. Was this bid posted to the nationwide free bid notification website at www.mygovwatch.com/free?
 - No.
4. Other than your own website, where was this bid posted?
 - DemandStar and Vendor Registry.
5. Please confirm what fiber core do you need (OS1/OS2, OM1.OM2.OM3, OM4) This information is missing from the file under items # 33 to 43.
 - OM4.
6. Can we use Generic Material?
 - No.
7. Kindly requesting the site Address for this project and if there are drawing plans ready, please provide.
 - All City owned and operated facilities. Additional details can be provided to the award firm.
8. Can the Exhibit B: Pricing Sheet be provided as an excel spreadsheet?
 - Yes, please see attached document.
9. Will the Q&A be posted on an addendum?
 - Yes.
10. Can you provide part numbers for the Wireless Parts you are requesting?
 - Yes, please see attached Exhibit B – Pricing Sheet.
11. My question is with regard to insurance coverages: are ALL those coverages required? Specifically the cyber coverage and crime insurance, these are not normal required by government agencies.



City of Doral

ITB No. 2021-05 - Telecommunications Wiring Services

Addendum No. 1

\$5million in cyber is not necessarily needed from a wiring vendor since we don't touch your networks.

- Pending final determination from Risk and City Attorney. Final limits will be provided via another addendum.

12. Can you please paste here the link to the solicitation package?

- <https://www.cityofdoral.com/all-departments/procurement-division/bid-opportunities-ii/listing/?id=dc4653a0-9264-eb11-a812-001dd8009229>

13. A question was previously asked with regard to generic materials... however, did the city specify which brands they require or typically use? Leviton, Otronics, Berktek, Corning, etc.?

- Yes, please see attached Exhibit B – Pricing Sheet.