



City of Doral

RFP No. 2021-09

Construction of Pedestrian Bridge – Design Build

Addendum No. 10

Financial Projects Number(s): 441642-1-58-01
Contract Number: RFP No. 2021-09

Below are changes/ updates regarding this project. This Addendum is and does become a part of the above-mentioned solicitation. This addendum is issued to modify the subject solicitation as follows:

1. RFP Pg. 55 of 76 – Structure Plans: Bridge Design Analysis:

- The elevators are to be considered optional as a portion of the design. When excluding the elevators from the pedestrian bridge design, the Design-Build Firm shall prepare pedestrian bridge plans in general conformance with the Approved Pedestrian Bridge Concept Design (Reference Document R-1) to maintain similar aesthetic appearance. The Design-Build Firm shall submit the proposed the design to the City for review and approval. **Elevator requirements if included as a portion of the design shall be per the RFP.**
- j. ~~Elevators—All elevator components shall be designed and rated for continuous use with a minimum 120 operations per hour. Elevator systems, components and finishes shall be designed for semi-protected outdoor use. Elevators shall have a 5,000-pound capacity and a minimum vertical speed of 150 feet per minute at rated capacity. Each elevator shall have two-speed or center opening doors with a clear width of 4 feet six inches. Elevators may also be used to carry maintenance lift equipment. Elevator cabs, doors and entrances shall have highly durable finishes such as Type 304 stainless that are textured where applicable for graffiti and vandal resistance. Each elevator cab and hoistway shall have one or more transparent walls that allow effective visual surveillance of the elevator cab interior by passersby.~~