



City of Doral
ITB No. 2022-21
Fire Alarm Monitoring, Maintenance, Inspections,
And Repairs at City Facilities
Addendum No. 1

Below are questions/ clarifications that were received regarding this project as well as the City's responses. This Addendum is and does become a part of the above-mentioned solicitation. This addendum is issued to modify the subject solicitation as follows:

**Please note: This Addendum extends the bid due date to:
Monday, July 18th, 2022, at 10:00 A.M.**

1. Can you provide a list of current equipment and inspections?
 - Please see attached below.
2. How are the panel currently monitored? Is the City open to wireless or other options?
 - Via Phone Lines.
 - The City will consider other options if proposed.
3. Where can the solicitation document be found?
 - <https://www.cityofdoral.com/all-departments/procurement-division/bid-opportunities-ii/listing/?id=8b64a8be-75ee-ec11-bb3b-001dd800a870>

**ITB No. 2022-21 Fire Alarm Monitoring, Maintenance, Inspections, and Repairs at City Facilities
- Bid Opening**

Mon, Jul 18, 2022, 10:00 AM - 11:00 AM (EDT)

Please join my meeting from your computer, tablet, or smartphone.

<https://meet.goto.com/389499373>

You can also dial in using your phone.

United States: +1 (571) 317-3112

Access Code: 389-499-373

Schedule 1- Buildings equipment inventory

City Hall - 8401 NW 53rd Tr

| Device description | Manufacture | Model | Quantity | Notes |
|-------------------------|-------------|--------------|----------|-------|
| Alarm panels | FCI | E3 series | 1 | |
| Batteries | | 12V 7.2 AH | 10 | |
| Power supply | Wheelock | PS-8 | 4 | |
| Voice evac | Notifier | E3 series | 2 | |
| Annunciator | FCI | LCD-7100 | 1 | |
| Speaker strobe | Wheelock | E60-34MCC-FW | 76 | |
| Strobe | Wheelock | STWC | 47 | |
| Ionization Detectors | FCI | ASD-PL2F | 30 | |
| Photoelectric detectors | FCI | ASD-PL2F | 6 | |
| Duct detectors | FCI | ASD-PL2F | 4 | |
| Heat detectors | FCI | ATD- RL2F | 2 | |
| Manual pull stations | FCI | MS-7S | 8 | |

Police – 6100 NW 99th Av

| Device description | Manufacture | Model | Quantity | Notes |
|-------------------------|-------------|--------------|----------|-------|
| Alarm panels | FCI | 7100 | 1 | |
| Batteries | | 12V 7.2 AH | 14 | |
| Power supply | Wheelock | PS-8 | 2 | |
| | FCI | GFPS-9 | 3 | |
| Voice evac | Wheelock | SP-40-S | 2 | |
| Annunciator | FCI | LCD-7100 | 1 | |
| Speaker strobe | Wheelock | E70-24MCW-FW | 44 | |
| Strobe | Wheelock | STW | 65 | |
| Photoelectric detectors | FCI | ASD-PL2F | 20 | |
| Duct detectors | FCI | ASD-PL2F | 7 | |
| Heat detectors | FCI | ATD-RL2F | 8 | |
| Manual pull stations | FCI | MS-7S | 18 | |

Training Center – 3719 NW 97 Av

| Device description | Manufacture | Model | Quantity | Notes |
|-------------------------|-------------|------------|----------|---------------------------------------|
| Alarm panels | Siemens | FC 901-U3 | 1 | |
| Batteries | | 12V 12AH | 2 | |
| | | 12V 7.2 AH | 6 | |
| Power supply | Siemens | Pad-3 | 1 | |
| Voice evac | Mircom | | 1 | |
| Surge protector | Ditek | DTK-T551 | 1 | |
| Speaker strobe | Siemens | | 19 | |
| Suppression releasing | Fike | 10-063 | 1 | IT room, tank @closet across the hall |
| Strobe | Siemens | | 10 | |
| Air sampling Detectors | Siemens | | 1 | |
| Photoelectric detectors | Siemens | | 1 | |
| Valve switch | | | 2 | Waterflow and tamper on north riser |
| Addressable module | Siemens | FDCI0422 | 1 | Generator |
| Manual pull stations | Siemens | | 6 | |

Schedule 2- Parks equipment inventory

Morgan Levy Park – 5300 NW 102 Av

| Device description | Manufacture | Model | Quantity | Notes |
|---------------------------|--------------------|--------------|-----------------|--------------|
| Alarm panels | Simplex | 1040 | 1 | |
| Batteries | | 12V 12 AH | 3 | |
| Annunciator | Simplex | 4010 | 1 | |
| Horn strobe | Simplex | 4906-9127 | 12 | |
| Strobe | Simplex | 4904-9184 | 2 | |
| | | 4906-9101 | 1 | |
| Duct Detector | Simplex | 9714-4098 | 1 | |
| Photoelectric detectors | Simplex | 9714-4098 | 30 | |
| External dialer | Silent knight | 5104B | 1 | |
| Heat detectors | Simplex | | 1 | |
| Manual pull stations | Simplex | 4099-9001 | 9 | |

Doral Glades Park – 7600 NW 98th Place

| Device description | Manufacture | Model | Quantity | Notes |
|---------------------------|--------------------|--------------|-----------------|--------------|
| Alarm panels | Edwards | i- 064 | 1 | |
| Batteries | | 12V 12 AH | 2 | |
| Horn strobe | Edwards | EG1F-VM | 18 | |
| Photoelectric detectors | Edwards | SIGA- OSD | 1 | |
| Manual pull stations | Edwards | SIGA-278 | 7 | |

Doral Legacy Park (field) – 11400 NW 82nd Street

| Device description | Manufacture | Model | Quantity | Notes |
|---------------------------|--------------------|--------------|-----------------|--------------|
| Alarm panels | Fire Lite | MS-9200 UDLS | 1 | |
| Batteries | | 12V 7.2AH | 2 | |
| Horn strobe | Fire Lite | P4HR | 3 | |
| Strobe | Fire Lite | SR | 3 | |
| Photoelectric detectors | Fire Lite | 2151 | 1 | |
| Manual pull stations | Fire Lite | BG-12 LX | 3 | |

Doral Legacy Park (Recreational center) – 11400 NW 82nd Street

| Device description | Manufacture | Model | Quantity | Notes |
|---------------------------|--------------------|--------------|-----------------|--------------|
| Alarm panels | Fire Lite | MS-9200 UDLS | 1 | |
| Batteries | | 12V 7.2 AH | 6 | |
| | | 12V 18 AH | 2 | |
| Annunciator | Fire Lite | ANN-80 | 1 | |
| Speaker strobe | Fire Lite | SPSR | 57 | |
| Strobe | Fire Lite | SR | 12 | |
| Voice evac | Fire Lite | ECC 50/100 | 1 | |
| Duct Detector | Fire Lite | D355 | 2 | |
| | Fire Lite | SD355 | 1 | |
| Photoelectric detectors | Fire Lite | SD355 | 30 | |
| Power supply | Honeywell | HPFF12 | 3 | |

| | | | | |
|----------------------|-----------|---------|----|--|
| Remote voice evac | Fire Lite | ECC-RM | 1 | |
| Manual pull stations | Fire Lite | BG12 LX | 10 | |

Doral Meadow Park– 11555 NW 58 Street

| Device description | Manufacture | Model | Quantity | Notes |
|---------------------------|--------------------|--------------|-----------------|--------------|
| Alarm panels | Fire Lite | ES-50X | 1 | |
| Batteries | | 12V 18AH | 2 | |
| Horn strobe | Fire Lite | P4HR | 4 | |
| Strobe | Fire Lite | SR | 5 | |
| Photoelectric detectors | Fire Lite | 2151 | 13 | |
| Manual pull stations | Fire Lite | BG-12 LX | 8 | |
| Duct Detector | Fire Lite | SD355 | 2 | |
| Heat Detector | Fire Lite | FST-851 | 1 | |