



City of Doral
ITB No. 2022-21
Fire Alarm Monitoring, Maintenance, Inspections,
And Repairs at City Facilities
Addendum No. 2

Below are questions/ clarifications that were received regarding this project as well as the City's responses. This Addendum is and does become a part of the above-mentioned solicitation. This addendum is issued to modify the subject solicitation as follows:

1. What frequency of NFPA 72 Inspections are you requiring (i.e. - Annual, Semi-Annual, and/or Quarterly).?
 - Quarterly inspections.
2. Are the fire alarm panels Certificated with a UL or ETL Certificate?
 - UL certification
3. Can you define what is to be included for "Maintenance" – Labor Only OR Parts & Labor?
 - Labor only.
4. Please provide clarification and authorization for bidders to utilize 3rd party subcontractor(s) for proprietary fire alarm system parts and programming assistance.
 - The Awarded Provider may not subcontract any portion of the scope of services mentioned as part of this RFP without the prior written authorization from the City's representative or designee
5. Can you Clarify Section 3.7.1 "This is in addition to documentation required" – Are you referring to a work acknowledgement type document?
 - Yes. The City is looking for a document summarizing any serviced, tested, altered, or inspected fire alarm.