

**Department of Regulatory and Economic Resources
Miami-Dade County
Plan Review Summary**

**Process Number: CITY OF DORAL
NW 33 ST DRAINAGE**

FINAL CORE REVIEW DATE: 5/17/2022

OVERALL STATUS: Overall Approval

PROJECT DETAILS:

FOLIO: 35-3027-052-0030

ADDRESS: NW 87 AVE TO NW 82 AVE , DOR

PERMIT TYPE DESC.:

CONTACT DETAILS:

NAME: MAYRA SAAVEDRA

EMAIL: mayra.saavedra@stantec.com

PHONE #: 786-614-2179

DISAPPROVAL CODES:

Disapproval Code 01: 0291 - Paving and Drainage plans approval required. Contact the Water Control Section at 701 NW 1 CT. 6th Floor, Miami Fl.(305) 372-6681

TASK	REVIEWED BY	STATUS DATE	STATUS
Initial Core Review	Leysi Castellanos	05/17/2022	Reviewed

Comments: Permit for Paving and Drainage improvements at NW 33RD STREET FROM NW 87TH AVE TO NW 82ND AVE / City of Doral Project# 215616857 / Scope of work includes paving and drainage work only. For 291 - Paving and Drainage Section Approval is required.

P D Review	Marsel Fakrutdinov	05/17/2022	Approved
-------------------	--------------------	------------	----------

Comments: The Water Control Section does not have any objections for the proposed work of the drainage improvement.

Note.

1. A Class V Permit is required for any temporary or emergency dewatering activities during the construction of the proposed project.
2. The erosion and sedimentation control measures should be implemented during the proposed construction activities.

Final Core Review	Erica Miller-King	05/17/2022	Overall Approval
--------------------------	-------------------	------------	------------------

Comments: 5/17/2022 Paving and Drainage approved---EMM

PLAN CONDITIONS:

NO CONDITIONS

PLAN REVIEW FEES (FEES ARE SUBJECT TO CHANGE PENDING FINAL APPROVAL):

FEE CODE	DESCRIPTION	USER	DATE	UNIT	TOTAL
D062	Commercial & Multifam Min Review	MILLEE	05/17/2022	1	\$90.00
D069	Paving And Drainage Major Rev	MILLEE	05/17/2022	1	\$210.00
Total					\$300.00

FOR MORE INFORMATION PLEASE CONTACT:

YOUR DERM CORE REVIEWER: miller@miamidade.gov

DERM PERMITTING AND INSPECTION CENTER, 11805 SW 26 ST, 786-315-2800

DERM OVERTOWN TRANSIT CENTER, 701 NW 1 CT, 305-372-6899

Coastal: dermcr@miamidade.gov

EQCB: eqcb@miamidade.gov

Specialty Engineering Reviews (industrial, storage tanks, industrial waste pretreatment, asbestos, paving & drainage, trees): dermengreviews@miamidade.gov

Tree Permit applications: dermtreeprogram@miamidade.gov

Water Control: dermwatercontrol@miamidade.gov

Wetlands: dermwetlands@miamidade.gov